



Alabama Department of Environmental Management
adem.alabama.gov

1400 Coliseum Blvd. 36110-2400 ■ Post Office Box 301463
Montgomery, Alabama 36130-1463
(334) 271-7700 ■ FAX (334) 271-7950

January 22, 2014

CERTIFIED MAIL 91 7199 9991 7032 3101 7358

Mr. Tony Becnel
Director of Operations
Dupre' Logistics, LLC
201 Energy Parkway, Suite 500
Lafayette, Louisiana 70508

ADMINISTRATIVE ORDER

Re: ADMINISTRATIVE ORDER NO. 14-033-UST
Dupre' Logistics, LLC

Dear Mr. Becnel:

Enclosed please find **Administrative Order No. 14-033-UST**, which requires you to take certain actions in regard to alleged violations of the Alabama Underground Storage Tank (UST) and Wellhead Protection Act. In issuing this Order, the Department took into consideration all available information concerning these violations, including any written response or oral comments submitted on behalf of the operator/owner.

Please be advised that failure to comply with the terms of this Order can result in penalties of up to \$25,000.00 per day for each violation as well as possible criminal penalties. Pursuant to Code of Alabama 1975, §22-22A-7(c)(1), as amended, this Order may be appealed by filing a request for a hearing before the Environmental Management Commission which should comply with the requirements of ADEM Admin. Code Chapter 335-2-1. Copies of ADEM Admin. Code, Div. 2, Environmental Management Commission regulations can be viewed or downloaded from ADEM's webpage at <http://www.adem.state.al.us> or may be obtained by submitting a request in writing to ADEM – Permits and Services Division.




Mr. Tony Becnel
Dupre' Logistics, LLC
Page 2

Please note the issuance date of January 22, 2014. **Payment of the civil penalty in the amount of \$2,500.00 is due on or before March 10, 2014** and should be submitted to the ADEM Office of General Counsel at the Above Montgomery address.

Should you have any questions concerning this matter, please contact Mr. Lee Davis, Chief of the UST Compliance Section, in Montgomery at (334) 271-7759.

Sincerely,

A handwritten signature in black ink, appearing to read 'Phillip D. Davis', with a long horizontal flourish extending to the right.

Phillip D. Davis, Chief
ADEM Land Division

PDD/SSM/MLD/ATC/rh

Enclosure

cc: Sonja M. Massey, Chief
ADEM Groundwater Branch, Land Division


ADEM Office of General Counsel

ADMINISTRATIVE ORDER CERTIFICATE OF SERVICE

I, Phillip D. Davis, hereby certify that I have this date served the foregoing Administrative Order on upon the person listed below by regular United States Mail, properly addressed and postage prepaid to:

Mr. Tony Becnel
Director of Operations
Dupre' Logistics, LLC
201 Energy Parkway, Suite 500
Lafayette, Louisiana 70508

Done this 22 day of January, 2014.


Signature

**ALABAMA DEPARTMENT
OF ENVIRONMENTAL MANAGEMENT**

In The Matter Of:)

Dupre' Logistics, LLC)
Russellville, Colbert County, Alabama)

ADMINISTRATIVE ORDER

No. 14-033-UST

FINDINGS

Pursuant to the provisions of the Alabama Environmental Management Act, §§ 22-22A-1 to 22-22A-16, Ala. Code, as amended; the Alabama Underground Storage Tank and Wellhead Protection Act, §§ 22-36-1 to 22-36-10, Ala. Code, as amended; and the ADEM Administrative Code of Regulations (hereinafter "ADEM Admin. Code r.") promulgated pursuant thereto, the Alabama Department of Environmental Management (hereinafter the "Department" or "ADEM") makes the following FINDINGS:

1. Dupre' Logistics, LLC (hereinafter "the Owner") is a regulated substance deliverer.
2. ADEM is a duly constituted agency of the State of Alabama pursuant to §§ 22-22A-1 to 22-22A-16, Ala. Code, as amended.
3. Pursuant to § 22-22A-4(n), Ala. Code, as amended, ADEM is the State Environmental Control Agency for the purposes of federal environmental law, including 42 U.S.C. §§ 6991 to 6991(m), as amended.
4. ADEM is authorized to administer and enforce the provisions of the Alabama Underground Storage Tank and Wellhead Protection Act, §§ 22-36-1 to 22-36-10, Ala. Code, as amended.
5. Based upon an inspection of the UST facility and/or a review of facility records, the Department has documented the violations alleged herein.
6. Pursuant to ADEM Admin. Code r. 335-6-15-.45(3), upon implementation of delivery prohibition, it shall be unlawful for any regulated substance deliverer to deliver a regulated substance, and it shall be unlawful for owners and operators of UST systems to accept delivery of a regulated substance to an underground storage tank facility that is under delivery prohibition.

7. The Owner, a regulated substance deliverer, delivered a regulated substance to an underground storage tank facility that was under delivery prohibition.

8. The regulated substance was delivered on September 12, 2013, to County Line Package Store located at 125 Highway 247, Russellville, Colbert County, Alabama while they were on delivery prohibition. The facility ID No. of County Line Package Store is 15968-033-007412.

9. Pursuant to § 22-22A-5(18)(c), Ala. Code, as amended, in determining the amount of any penalty, the Department must give consideration to the seriousness of the violation, including any irreparable harm to the environment and any threat to the health or safety of the public; the standard of care manifested by such person; the economic benefit which delayed compliance may confer upon such person; the nature, extent and degree of success of such person's efforts to minimize or mitigate the effects of such violation upon the environment; such person's history of previous violations; and the ability of such person to pay such penalty. Any civil penalty assessed pursuant to this authority shall not exceed \$25,000.00 for each violation, provided however, that the total penalty assessed in an order issued by the Department shall not exceed \$250,000.00. Each day such violation continues shall be a separate violation.

In arriving at the civil penalty assessed in this matter, the Department has considered the following:

A. Seriousness of the Violation:

The Owner/Deliverer did not ensure that the facility was not on delivery prohibition. The violations impede the Department's regulatory authority over USTs for threats to public health, safety and the environment.

B. Standard of Care:

The Owner/Deliverer did not exhibit a standard of care commensurate with applicable regulatory requirements.

C. Economic Benefit Which Delayed Compliance May Have Conferred:

The Department has been unable to ascertain if there has been a significant economic benefit conferred on the Owner.

D. Efforts to Minimize or Mitigate the Effects of the Violation Upon the Environment:

There are no known environmental effects as a result of the alleged violations.

E. History of Previous Violations:

The Owner/Deliverer does not have a history of previous violations.

F. Ability to Pay:

The Owner/Deliverer has not alleged an inability to pay the civil penalty.

- G. Other Factors: The Department has carefully considered the six statutory penalty factors enumerated in Ala. Code § 22-22A-5(18)c, as amended, as well as the need for timely and effective enforcement, and has concluded that a civil penalty in the amount of \$2,500.00 is appropriate, in keeping with a penalty range imposed by the Department for similar violations at other UST facilities, as follows (see attachment A):

<u>Violation Type</u>	<u>Penalty Range for Violation Type</u>
Unauthorized delivery to a facility on delivery prohibition	\$0 - \$25,000

ORDER

Based on the foregoing FINDINGS and pursuant to §§ 22-22A-5(1), 22-22A-5(10), 22-22A-5(12) and 22-22A-5(18), 22-36-9, Ala. Code, as amended, it is hereby ORDERED:

A. That, within forty-five days of the effective date of this Administrative Order, the Owner shall pay to the Department a civil penalty in the amount of \$2,500.00 for the violations cited herein. Failure to pay the civil penalty within forty-five days of the effective date of this Administrative Order shall constitute cause for the Department to file a civil action in the Circuit Court of Montgomery County, Alabama. Payment shall be made by Cashier's Check or Money Order, payable to the Alabama Department of Environmental Management, and addressed as follows:

Office of General Counsel
Alabama Department of Environmental Management
P.O. Box 301463
Montgomery, Alabama 36130-1463


B. That, should any provisions of this Administrative Order be declared by a court of competent jurisdiction or the Environmental Management Commission to be inconsistent with Federal or State law, and therefore unenforceable, the remaining provisions hereof shall remain in full force and effect.

C. That, except as otherwise set forth herein, this Administrative Order is not and shall not be interpreted to be a permit or modification of a permit under Federal, State or local law, and shall not be construed to waive or relieve the Owner of the obligation to comply in the future with all applicable law.

D. That the issuance of this Administrative Order does not preclude the Department from seeking criminal fines or other appropriate sanctions or relief against the Owner of the violations cited herein.

E. That failure to comply with the provisions of this Administrative Order shall constitute cause for commencement of legal action by the Department against the Owner for recovery of additional civil penalties, criminal fines, or other appropriate sanctions or relief.

ORDERED and ISSUED this the 22 day of January, 2014.



Lance R. LeFleur
Director

ATTACHMENT A

Penalty Synopsis

Dupre' Logistics, LLC
201 Energy Pkwy., Suite 500
Lafayette, LA 70508

Violation*	Number of Violations*	Seriousness of Violation & Base Penalty*	Standard of Care*	History of Previous Violations*
ADEM Admin Code r. 335-6-15-.45(3) states that it shall be unlawful for any regulated substance deliverer to deliver a regulated substance, and it shall be unlawful for owners and operators of UST systems to accept delivery of a regulated substance to a UST facility that is under delivery prohibition.	1	\$1,250	\$1,250	\$0
Totals:	1	\$1,250	\$1,250	\$0

Economic Benefit*:	\$0
Mitigating Factors*:	\$0
Ability to Pay*:	\$0
Other Factors*:	\$0

Total Civil Penalty: \$2,500

Footnotes

* See the "Findings" of the Order for a detailed description of each violation and the penalty factors